

firefighter safety . . . and the codes

is there a connection?

Jim Tidwell, National Director

Fire Service Activities, International Code Council

- Number of firefighter fatalities (excluding WTC) is down 59% since 1977
- Contributing Factors:
 - Reduction in number of fires
 - PPE improvements
 - Training enhancements
 - Better fireground management
 - Physical Fitness Programs



WHILE THE NUMBER OF

FATALITIES HAS DROPPED BY

59% SINCE 1977, THE

NUMBER OF STRUCTURE

FIRES HAS DROPPED BY 54%



- The rate of deaths attributable to heart attacks have dropped by 27% since 1977, from 2.6 per 100,000 fires to 1.9 per 100,000 fires
- The rate of deaths from non-heart attack causes outside of structures dropped from 1.4 to .5 deaths per 100,000 fires, a 64% reduction!
- The rate of deaths from traumatic causes *inside* structure fires *increased over 60%* from 1.8 per 100,000 fires to 3 per 100,000 fires

While structure fires DECREASED by 54%, the rate of Firefighter fatalities attributable to traumatic causes inside structures INCREASED by 60%













What are we doing about it?

- Many code provisions address firefighter safety issues already.
- Firefighters/Fire Chiefs must become engaged in the fire prevention
- Fire Service has full and complete access to the International Code Council processes



What are we doing about it?

The International Fire Code includes the following language under Section 101.3, titled "Intent":

• "The purpose of this code is to establish the minimum requirements. . . and to provide safety to fire fighters and emergency responders during emergency operations"



What are we doing about it?

- Firefighter safety is enhanced by adopting and applying the IFC by:
 - Reducing the number of fires that occur
 - Limiting the fire spread when fires do occur, and
 - Providing specific protections for firefighters engaged in interior operations and other suppression activities



Specific Provisions:

- 3.11 Abandoned Premises
- 3.15.2.1-Clearance below ceilings
- 401.3.1 False Alarms
- 407.2 MSDS Required on site
- 407.6 & 407.6 HMIS & HMMP





Specific Requirements

- Chapter 5: Fire Service Features
 - Fire Apparatus Access Roads
 - Access to Stairways and Roofs
 - Trap Doors
 - Shaftways
 - Pitfalls
 - Fire Command Center







Specific Requirements

- Section 604 Emergency Power
- Section 606 Refrigeration Systems
- Section 607 Elevator Recall
- Section 905 Standpipe Systems
- Section 907.2.12.3 Fire Department Communications System
- Section 909 Smoke Control
- Section 910 Smoke & Heat Vents





Case Study: High Piled Stock Occupancies:

- Fire Department Access Roadways
 - Must be within 150 ft. of all portions of the exterior of the building
 - No exception for sprinklered buildings
- Fire Department Access Doors
 - Every 100 ft. or portion thereof
 - Ladder access to doors unacceptable
 - Only approved locking hardware





Case Study: High Piled Stock Occupancies:

- Smoke & Heat Vents
- Draft Curtains
- Maximum Pile Dimensions
- Maximum Pile Heights













Firefighter Safety is more than working out and wearing your PPE properly.

If you aren't applying the standards that your community has adopted to make buildings safer for the public, and the firefighters, you're risking the lives of your neighbors, and your brothers & sisters in the fire service.

Code enforcement may not be as sexy as fire suppression – but it provides for a much higher return on your tax dollar, and saves immeasurable expenses in workers' compensation, pain & suffering, and community angst from firefighter deaths & injuries





ENGAGE



